



Automatic Fire Sprinkler Systems
Backflow Preventers
Sales and Services 24 Hrs.

Masse Fire Protection Services

Masse Fire Protection Services



PO BOX #64
Pelham, NH 03076
603-635-3120

Hydrant Test Report

Date: 3/25/20 Time: 10:00P.M.

Property Name: 55 Summer St. Location: 55 Summer St. Walpole, Ma.

Manufacturer: Mueller Model: 1993

Flow Test

Gauge Hydrant # or Location: Past the post office Static: 70 p.s.i.

Residual: 65 p.s.i.

Flow Hydrant # or Location: Legacy Business Ctr. Pitot: 45 p.s.i.

Flow: 1130 GPM

Outlet diameter 2 1/2"

Booster pump on No

Witnessed By: Corey Grogg

Witnessed By: Water Dept.

Masse Fire Protection Services